

June 19, 1997

Refer to: HNG-14

Mr. J. M. Essex, P.E.  
Vice President, Sales  
Energy Absorption Systems, Inc.  
One East Wacker Drive  
Chicago, Illinois 60601

Dear Mr. Essex:

Your March 26 letter to Mr. Gerald L. Eller requested the Federal Highway Administration (FHWA) to accept the Brakemaster System as a National Cooperative Highway Research Program (NCHRP) Report 350 test level 3 (TL-3) terminal. To support this request, you provided copies of your March 1997 report, "BRAKEMASTER System Qualification to NCHRP 350", which included information on three tests conducted in 1989 under NCHRP Report 230 guidelines and on five more recent tests by E-TECH Testing Services, Inc, conducted under NCHRP Report 350 guidelines. In addition to these test reports, drawings, photographs, and videotapes of the full-scale crash tests were also submitted. The results of the certification tests are summarized in Enclosure 1 for ready reference. In response to questions raised by my staff, you submitted supplemental information with your letters dated April 4, April 22, May 7, and June 9.

We note that the design for which you have requested FHWA acceptance (Enclosure 2) is identical to the NCHRP Report 230 Brakemaster terminal except for a new alternative end anchor detail. In addition to the original concrete footing anchor design, you have requested acceptance of an anchor assembly consisting of two 1981-mm long TS-203x152x4.8 steel tubes connected by a steel anchor (tension) strap 9.5-mm thick as detailed in drawing no. 9202024-0000 in Enclosure 2.

We agree that NCHRP Report 230 tests 44 and 45 correspond to NCHRP REPORT 350 tests 3-34 and 3-30, respectively, and that NCHRP Report 230 test S31 can be considered approximately equivalent to NCHRP Report 350 test 3-39 for the Brakemaster design features. We concur that all NCHRP Report 350 tests that were run (3-31, 3-32, 3-33, and 3-35) satisfactorily met appropriate evaluation criteria as noted in Enclosure 1. We have noted that test 3-35 was run twice, once with each of two different anchor designs, to show that, under maximum loading conditions, the recommended alternative anchor design, which has no soil bearing plates on the anchor tubes, performed as well as a developmental design, which incorporated shorter anchor tubes with soil bearing plates and a ground-level compression connecting strut and was used in three of the other NCHRP Report 350 certification tests (tests 3-31, 3-32 and 3-33).

Based on our review of the information presented, we have concluded that the Brakemaster design with either of the anchor assemblies shown in Enclosure 2 satisfies the NCHRP Report 350 evaluation criteria for a TL-3 terminal and that it may be used on the National Highway System (NHS) when selected by a highway agency. Since the Brakemaster is proprietary, all regulations regarding its use on Federal-aid projects (except non-NHS projects) remain applicable.

A copy of this letter and enclosures will be sent to the FHWA field offices for information.

Sincerely yours,









(original signed by David A. Price)

*for* Dwight A. Horne, Chief  
Federal-Aid and Design Division

2 Enclosures  
Acceptance Letter CC-41



TABLE 1 -- SUMMARY OF TEST RESULTS SUBMITTED FOR CERTIFICATION OF THE BRAKEMASTER TO NCHRP 350 STANDARDS

NCHRP Evaluation Criteria	NCHRP 350 Equivalent	Test ID	Test Conditions	Impact Speed (kn/hr)	Impact Angle (deg.)	Occupant Impact Velocity		Ridedown Accelerations		Overall Assessment	Anchor and soil types used	Justification of NCHRP 230 test inclusion
						Long. (m/sec)	Lateral (m/sec)	Long. (G)	Lateral (G)			
<b>NCHRP 230 Tests Included in Current Certification Program</b>												
230-44	3-34	074-57	(See below)									
230-45	3-30	074-56	(See below)									
230-S31	3-39	074-46	(See below)									
<b>NCHRP 350 Certification Tests for TL3, Redirective, Gating End Terminal</b>												
350-3-30	---	074-56		100.8	0	9.8	2.7	14.2	5.9	PASS <sup>a</sup>	Concrete pad	NCHRP 350 Test 3-30 is effectively equivalent to NCHRP 230 Test 45
350-3-31	---	01-7606-03		100.35	0	8.05	0.66	-14.13	-2.96	PASS <sup>b</sup>	5 ft foundation tube in weak soil (Appendix 2, Illustration D-3)	
350-3-32	---	01-7606-01		103.05	15	11.60	1.08	-16.57	6.21	PASS <sup>b</sup>	5 ft foundation tube in weak soil (Appendix 2, Illustration D-3)	
350-3-33	---	01-7606-02		93.34	14	7.46	0.49	-9.71	-3.40	PASS <sup>b</sup>	5 ft foundation tube in weak soil (Appendix 2, Illustration D-3)	
350-3-34	---	074-57		99.2	15	4.8	4.8	5.7	13.6	PASS <sup>a</sup>	Concrete pad	NCHRP 350 Test 3-34 is effectively equivalent to NCHRP 230 Test 44.
350-3-35	---	01-7606-04		99.37	21.0	6.73	1.27	-9.17	6.26	PASS <sup>b</sup>	Embedded (concrete) anchor in weak soil. (Appendix 2, Illustration D-6)	
350-3-35	---	01-7606-05		95.43 <sup>c</sup>	20.5	3.06	3.09	-10.34	10.65	PASS <sup>b,d</sup>	6 1/2 ft foundation tube in standard soil. (Appendix 2, Illustration D-8)	
350-3-39	---	074-46		97.6	17 <sup>d</sup>	5.8	4.5	13.5	11.7	PASS <sup>a</sup>	Concrete pad	NCHRP 350 Test 3-39 is effectively equivalent to NCHRP 230 Test S31.

<sup>a</sup> See Appendix 1 for summary of NCHRP 230 test results from original BRAKEMASTER certification program, and evaluation of test in accordance with NCHRP 350 criteria.

<sup>b</sup> See E-Tech report (Appendix 2) for full test details.

<sup>c</sup> Impact speed is 0.57 kph below recommended range; however, impact severity is within recommended range. This was judged to be acceptable because: Test 01-7606-04 demonstrated that the structure is fully adequate so long as the nose anchorage is stable, and test 01-7606-05 demonstrated that the foundation tube anchor is sufficiently stable.

<sup>d</sup> The impact severity is less than recommended, because the impact angle is less than recommended. This was judged to be acceptable for two reasons: First, the BRS functions identically regardless of the direction of overlap of the fender panels. As a result, it is always installed so that the panels overlap away from traffic and there are never any snag points presented to traffic. Secondly, the front anchor capacity was verified in test 01-7606-05 (NCHRP 350-3-35).

NOTE:  
DURING AN IMPACT, THE FENDER  
PANELS MAY FLARE OUT AS MUCH  
AS FOUR FEET ON BOTH SIDES.  
{1219mm}

NEW OR EXIST GUARDRAIL  
SUPPLIED BY OTHERS  
(SEE NOTE 2)

CAUTION: DO NOT ATTACH THE BRAKEMASTER SYSTEM  
DIRECTLY TO A RIGID CONCRETE BARRIER. A GUARDRAIL  
TRANSITION SECTION IS REQUIRED. CONTACT ENERGY  
ABSORPTION SYSTEMS AT (312) 467-6750 FOR MORE  
INFORMATION.

BIDIRECTIONAL INSTALLATION SHOWN

PARTS LIST

ITEM	STOCK NO.	DESCRIPTION	REQ'D
1	9202010-0000	ANCHOR ASSY, EMBEDDED, BRS	1
2	9204010-0000	BREAKAWAY ASSY	1
3	9206010-0000	BRAKE/TENSION SUPPORT ASSY	1
4	9208010-0000	CABLE/BRAKE ASSY	1
5	9210011-0000	DIAPHRAGM, BRS	3
6	9212010-0000	PANEL/STRAP ASSY	6
7	9214010-0000	TRANSITION STRAP ASSY	2

NOTES:  
1. MANUFACTURER RECOMMENDS A CROSS SLOPE OF NO MORE THAN 8% (5').  
2. DOWNSTREAM GUARDRAIL MUST BE ANCHORED TO WITHSTAND A TENSION OF 120,000 LBS. {534 kN}

MODEL NO. 106106BR55

ENERGY ABSORPTION SYSTEMS, INC.  
ENGINEERING AND RESEARCH DEPARTMENT

BRAKEMASTER SYSTEM (BRS)

GENERAL ASSEMBLY  
(BIDIRECTIONAL SYSTEM)





FIG 1

PARTS LIST			
ITEM	STOCK NO.	DESCRIPTION	REQ'D
1	9202021-0000	ANCHOR, EMBEDDED, W/DECAL	1
2	9202031-0000	SUPPORT, WOOD, 1 x 4 x 48	2
3	2699141-0100	BOLT, HK, 1/4x1 3/4, G2, P	4
4	2708271-0000	WASHER, FLAT, 1/4 x 1 1/2, G	4
5	2704151-0100	NUT, HK, 1/4, P	4



CAUTION: Proper placement of this assembly is critical to the final assembly of the system. Read and follow the installation instructions.

- NOTE
- ATTACH ITEMS 2 TO ITEM 1 AS SHOWN PRIOR TO INSTALLATION, REMOVE AFTER CONCRETE HAS SET.
  - NOTE DIRECTION OF ANCHOR: SEE DECAL.

ASSEMBLY NO. 9202010-0000

ENERGY ABSORPTION SYSTEMS, INC.  
ENGINEERING AND RESEARCH DEPARTMENT

BRAKEMASTER

ANCHOR ASSY, EMBEDDED, BRS

Q	X
W	X
PD	
S	X
H	X

Revisions	Date	Rev.	By	Chk	App	QC	Designed	Date
ITEM 3 WAS 2704151-0000 (1 3/4")	5/15/90	A	DL S	MD S			Drawn	MECH B 7/27/89
ADDED SIDE VIEW	5/17/90	A	DL S	305			Checked	B B A 11/13/89
REMOVED ITEM 6, WAS 2732451-0000	10/13/90	B	BO	MD S	305	RLP	Approved	Y b Kung 11/13/89
ADDED METRIC	1/20/91	C	DL S	DB	SP1		O.C.	R L Polman 11/13/89
ITEMS 3&5 WERE SCREW & NUT WASHER	1/20/91	D	TR	DB	SP1			
ITEM 5 WAS 2704151-0100 IN ERROR	6/1/92	E	TR	DB	SP1			


Tolerances:  
a. Angular ±  
b. Linear ±  
(Unless Otherwise Noted)

Material:  
SEE DETAIL DRAWINGS

REFERENCES

NEXT ASSEMBLY 92-00-03

SCALE (1:8)	DATE	REV NUMBER	SHEET	REV
1/8" = 1"	C	92-02-01	3421	E



PARTS LIST			
ITEM	STOCK NO	DESCRIPTION	REQ'D
1	9202025-0000	ANCHOR ADAPTER,BTS TO FOUND. TUBE	1.00
2	9202026-0000	ANCHOR STRAP,BRS	1.00
3	9202028-0000	FOUNDATION TUBE,78,BRS	2.00
4	2701992-0000	BOLT,HX,5/8X10,G5,G	2.00
5	2704191-0000	NUT,HX,5/8,G,RAIL	2.00
6	9202033-0000	ANCHOR PLUG, FOUNDATION TUBE	1.00

- NOTES:
- TIGHTEN NUTS 1/2 TURN BEYOND SNUG
  - EXTRA HOLES IN ITEM 2 ARE FOR  $\pm 50\text{mm}[2']$  TOLERANCE.
  - DIMENSIONS ARE IN mm [inches]

Revisions	Date	Rev	By	Ckd	App
WAS A SIZE BORDER	2/14/97	A	STI	KM	WCK
ADDED ITEM 6, REV'D ITEM 2	3/5/97	B	STI	KM	WCK
ADDED DIMENSIONS	3/24/97	C	JE	KM	WCK

REFERENCES

DRAWN	DATE
STI PAGE SEP	12/17/96
DESIGNED	DATE
B Krage	12/13/96
CHECKED	DATE
KRM	12/26/96
APPROVED	DATE
WCK	12/23/96
CAD FILE	
9202024-0000.dwg	
92-00-02	
NEXT ASSEMBLY 92-00-01	

ASSEMBLY NO 9202024-0000



ENERGY ABSORPTION SYSTEMS, INC.  
ENGINEERING AND RESEARCH DEPARTMENT

ANCHOR ASSY, FOUNDATION TUBE,  
6 1/2 FT., BRS

C TO C BRP